Vaibhavi Borewells

4½, 6½ Borewell Drillers

Dealers : All kinds of Borewell Pumpsets Installation & Servicing of Jet Air Compressor, Submersible Pumps

No. 1, 1st Floor, Bhuvaneswari Nagar, R.T. Nagar Post, Bangalore - 560 032.
Mob : 9845003097 / 9900252226

Ref.:

Date: 7/2/19

YIELD TEST CERTIFICATE

Name of Well Owner	:	AEE (projects division)
Address	:	Jayatarayanapura Projects. Mariyannapalya, mother teresa road.
Village / Hobli	:	B'lore
Taluk	:	B'lore
District	:	B'lore
Survey No. of Land	:	–
Date of Drilling	:	7-3-19
Depth of Casing Pipe	:	100 ft.
Size of Borewell	:	6.5"
Water Level	:	130 ft.
Remarks	:	–
Method of Test	:	Vaneech borewell.
Yield of Borewell	:	1.5"
Recommended Capacity Pump	:	17.5HP.

For VAIBHAVI BOREWELLS

Proprietor

For Vaibhavi Borewells

Proprietor

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

AE(HQ)

Vaibhavi Borewells

4½, 6½ Borewell Drillers

Dealers : All kinds of Borewell Pumpsets Installation & Servicing of Jet Air Compressor, Submersible Pumps

No. 1, 1st Floor, Bhuvaneswari Nagar, R.T. Nagar Post, Bangalore - 560 032.
Mob : 9845003097 / 9900252226

Ref. :

Date : 8/2/19.

YIELD TEST CERTIFICATE

Name of Well Owner	:	DEE (projects)
Address	:	Coffeeboard layout part.
Village / Hobli	:	Blore.
Taluk	:	Blore
District	:	Blore.
Survey No. of Land	:	—
Date of Drilling	:	8-2-19.
Depth of Casing Pipe	:	140 ft.
Size of Borewell	:	6.5"
Water Level	:	130 ft
Remarks	:	—
Method of Test	:	V-notch.
Yield of Borewell	:	2"
Recommended Capacity Pump	:	17.5 HP

For VAIBHAVI BOREWELLS

Proprietor

For **Vaibhavi Borewells**

Proprietor

AE(WS)

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Vaibhavi Borewells

4½, 6½ Borewell Drillers

Dealers : All kinds of Borewell Pumpsets Installation & Servicing of Jet Air Compressor, Submersible Pumps

No. 1, 1st Floor, Bhuvaneswari Nagar, R.T. Nagar Post, Bangalore - 560 032.
Mob : 9845003097 / 9900252226

Ref. :

Date : 11/2/19.

YIELD TEST CERTIFICATE

Name of Well Owner	:	EE (projects)
Address	:	Jakkur layout 7th Block.
Village / Hobli	:	Bllore
Taluk	:	Bllore
District	:	Bllore.
Survey No. of Land	:	–
Date of Drilling	:	11/2/19
Depth of Casing Pipe	:	100ft
Size of Borewell	:	6½"
Water Level	:	100ft.
Remarks	:	–
Method of Test	:	V-nath borwell.
Yield of Borewell	:	3"
Recommended Capacity Pump	:	12.5HP

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For VAIBHAVI BOREWELLS

For **Vaibhavi Borewells**

Proprietor

Proprietor

WATER WELLS

Specialist in : Ground Water Exploration, Development, Management and Rejuvenation

GEOLOGICAL - GEOHYDROLOGICAL - GEOPHYSICAL REPORT

V. APRAMEYA MURTHY, B.Sc (HONS), M.Sc
Ex-Officio RDPR, Department
744, 7th A Cross, A Sector
Yelahanka New Town, Bangalore - 560 064.

MOB : 94484 19262
RES : 080-28561744

Date : 5/2/19

1. Name : Assistant Executive Engineer: Projects Division: Drilling of borewells.			
2. Address : coffee board layout. Survey No.: –		Taluk :	
		Dist :	
3. Topography of the area. Park.			
4. Geology of the area. –			
5. Geohydrological condition of the area		Good.	
6. Survey conducted for	A. Type of Area	Agriland / Site / Layout /	
	B. Purpose	Irrigation / Domestic / Water Supply	
7. Method of Survey Employed :		Geological - Geophysical - Geohydrological	
8. RECOMMENDATION	A. Type of well	Borewells - Vnach.	
	B. Location	coffeeboard layout park.	
	C. Depth	1350 ft.	
	D. Probable casing	–	
9. YIELD EXPECTED*		2"	
10. SPECIAL RECOMMENDATION IF ANY			

*Conditions Apply.

Asst Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For WATER WELLS

Geologist

WATER WELLS

Specialist in : Ground Water Exploration, Development, Management and Rejuvenation

GEOLOGICAL - GEOHYDROLOGICAL - GEOPHYSICAL REPORT

V. APRAMEYA MURTHY, B.Sc (HONS), M.Sc
Ex-Officio RDPR, Department
744, 7th A Cross, A Sector
Yelahanka New Town, Bangalore - 560 064.

MOB : 94484 19262
RES : 080-28561744

Date : 5/2/19

1. Name : Assistant Executive Engineer. (projects division)			
2. Address : Madyannapalya.		Taluk :	
Survey No.: –		Dist :	
3. Topography of the area.		Residential area.	
4. Geology of the area.		–	
5. Geohydrological condition of the area		–	
6. Survey conducted for	A. Type of Area	Agriland / Site / Layout /	
	B. Purpose	Irrigation / Domestic / Water Supply	
7. Method of Survey Employed :		Geological - Geophysical - Geohydrological	
8. RECOMMENDATION	A. Type of well	V-nach borewell.	
	B. Location	–	
	C. Depth	1200 ft	
	D. Probable casing	–	
9. YIELD EXPECTED*		2 lpl	
10. SPECIAL RECOMMENDATION IF ANY		–	

*Conditions Apply.

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For WATER WELLS

Geologist

WATER WELLS

Specialist in : Ground Water Exploration, Development, Management and Rejuvenation

GEOLOGICAL - GEOHYDROLOGICAL - GEOPHYSICAL REPORT

V. APRAMEYA MURTHY, B.Sc (HONS), M.Sc
Ex-Officio RDPR, Department
744, 7th A Cross, A Sector
Yelahanka New Town, Bangalore - 560 064.

MOB : 94484 19262
RES : 080-28561744

Date : 5/2/19

1. Name : Assistant Executive Engineer (Project division)			
2. Address : Jakkur layout - 7th cross Survey No.:		Taluk :	Bangalore.
		Dist :	
3. Topography of the area.		Residential area.	
4. Geology of the area.		gmd.	
5. Geohydrological condition of the area		—	
6. Survey conducted for	A. Type of Area	Agriland / Site / Layout /	
	B. Purpose	Irrigation / Domestic / Water Supply	
7. Method of Survey Employed :		Geological - Geophysical - Geohydrological	
8. RECOMMENDATION	A. Type of well	V-nach borwell.	
	B. Location	Jakkur layout.	
	C. Depth	1100 ft	
	D. Probable casing	—	
9. YIELD EXPECTED*		2.5"	
10. SPECIAL RECOMMENDATION IF ANY			

*Conditions Apply.

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For WATER WELLS

Geologist

WATER WELLS